

## Schedule 11—Placard and manifest quantities

(regulations 347 to 350, 361, 390 and 391)

**Table 11.1**

<b>Item</b>	<b>Column 1 Description of hazardous chemical</b>	<b>Column 2 Placard quantity</b>	<b>Column 3 Manifest quantity</b>
<b>Flammable gases</b>			
1	Flammable gases—category 1A, category 1B or any combination of those categories	200 L	5,000 L
<b>Gases under pressure</b>			
2	Gases under pressure—with acute toxicity, category 1, 2, 3 or 4	50 L	500 L
3	Gases under pressure—with skin corrosion, category 1A, 1B or 1C	50 L	500 L
4	Gases under pressure—not specified elsewhere in this table	1,000 L	10,000 L
<b>Flammable liquids</b>			
5	Flammable liquids—category 1	50 L	500 L
6	Flammable liquids—category 2	250 L	2,500 L
7	Flammable liquids—category 3	1,000 L	10,000 L
8	Flammable liquids—any combination of chemicals from items 5 to 7 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 L	10,000 L
9	Flammable liquids—category 4	10,000 L	100,000 L
<b>Self-reactive substances</b>			
10	Self-reactive substances—type A	5 kg or 5 L	50 kg or 50 L
11	Self-reactive substances—type B	50 kg or 50 L	500 kg or 500 L
12	Self-reactive substances—any of types C to F	250 kg or 250 L	2,500 kg or 2,500 L
<b>Flammable solids</b>			
13	Flammable solids—category 1	250 kg	2,500 kg
14	Flammable solids—category 2	1,000 kg	10,000 kg
15	Flammable solids—any combination of chemicals from items 11 to 14 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Pyrophoric liquids and pyrophoric solids</b>			
16	Pyrophoric liquids and pyrophoric solids—category 1	50 kg or 50 L	500 kg or 500 L
<b>Self-heating substances and mixtures</b>			
17	Self-heating substances and mixtures—category 1	250 kg or 250 L	2,500 kg or 2,500 L

**Schedule 11** Placard and manifest quantities

<b>Item</b>	<b>Column 1 Description of hazardous chemical</b>	<b>Column 2 Placard quantity</b>	<b>Column 3 Manifest quantity</b>
18	Self-heating substances and mixtures—category 2	1,000 kg or 1,000 L	10,000 kg or 10,000 L
19	Self-heating substances and mixtures—any combination of chemicals from items 16 to 18 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Substances which in contact with water emit flammable gas</b>			
20	Substances which in contact with water emit flammable gas—category 1	50 kg or 50 L	500 kg or 500 L
21	Substances which in contact with water emit flammable gas—category 2	250 kg or 250 L	2,500 kg or 2,500 L
22	Substances which in contact with water emit flammable gas—category 3	1,000 kg or 1,000 L	10,000 kg or 10,000 L
23	Substances which in contact with water emit flammable gas—any combination of chemicals from items 20 to 22 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Oxidising liquids and oxidising solids</b>			
24	Oxidising liquids and oxidising solids—category 1	50 kg or 50 L	500 kg or 500 L
25	Oxidising liquids and oxidising solids—category 2	250 kg or 250 L	2,500 kg or 2,500 L
26	Oxidising liquids and oxidising solids—category 3	1,000 kg or 1,000 L	10,000 kg or 10,000 L
27	Oxidising liquids and oxidising solids—any combination of chemicals from items 24 to 26 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Organic peroxides</b>			
28	Organic peroxides—type A	5 kg or 5 L	50 kg or 50 L
29	Organic peroxides—type B	50 kg or 50 L	500 kg or 500 L
30	Organic peroxides—any of types C to F	250 kg or 250 L	2,500 kg or 2,500 L
31	Organic peroxides—any combination of chemicals from items 29 and 30 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	250 kg or 250 L	2,500 kg or 2,500 L
<b>Acute toxicity</b>			
32	Acute toxicity—category 1	50 kg or 50 L	500 kg or 500 L
33	Acute toxicity—category 2	250 kg or 250 L	2,500 kg or 2,500 L
34	Acute toxicity—category 3	1,000 kg or 1,000 L	10,000 kg or 10,000 L

<b>Item</b>	<b>Column 1 Description of hazardous chemical</b>	<b>Column 2 Placard quantity</b>	<b>Column 3 Manifest quantity</b>
35	Acute toxicity—any combination of chemicals from items 32 to 34 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Skin corrosion</b>			
36	Skin corrosion—category 1A	50 kg or 50 L	500 kg or 500 L
37	Skin corrosion—category 1B	250 kg or 250 L	2,500 kg or 2,500 L
38	Skin corrosion—category 1C	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Corrosive to metals</b>			
39	Corrosive to metals—category 1	1,000 kg or 1,000 L	10,000 kg or 10,000 L
40	Corrosive to metals—any combination of chemicals from items 36 to 39 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	1,000 kg or 1,000 L	10,000 kg or 10,000 L
<b>Unstable explosives</b>			
41	Unstable explosives	5 kg or 5 L	50 kg or 50 L
<b>Unstable chemicals</b>			
42	Unstable chemicals—any combination of chemicals from items 10, 28 and 41 where none of the items exceeds the quantities in column 2 or 3 of that item on its own	5 kg or 5 L	50 kg or 50 L
<b>Aerosols</b>			
43	Aerosols—category 1, category 2, category 3 or any combination of those categories	5,000 L	10,000 L

Note 1: In item 2, Gases under pressure with acute toxicity, category 4 only applies up to a LC50 of 5,000 ppmV. This is equivalent to dangerous goods of Division 2.3.

Note 2: Item 43 includes flammable aerosols.

## 1 Determination of classification of flammable liquids

For the purposes of this table, if a flammable liquid category 4 is used, handled or stored in the same spill compound as one or more flammable liquids of categories 1, 2 or 3, the total quantity of flammable liquids categories 1, 2 or 3 must be determined as if the flammable liquid category 4 had the same classification as the flammable liquid in the spill compound with the lowest flash point.

Example: For placarding and manifest purposes, a spill compound containing 1 000 L of flammable liquid category 1 and 1 000 L of flammable liquid category 4 is considered to contain 2 000 L of flammable liquid category 1